


**PERFORMANCE TESTS IN ACCORDANCE WITH
AAMA/WDMA/CSA 101/I.S.2/A440-08 & A440S1-09**



Report No.:
AI-04203-G1

Product Manufacturer:

LEPAGE MILLWORK
141, CHEMIN DES RAYMOND, C.P. 1298
RIVIÈRE-DU-LOUP, QUEBEC
G5R 4L9
(418) 862-2611

Test Report Summary:

Product type: Wooden Fixed Window
Product series/model: H-100 Wood Fixed Hung Window


Primary product designator: **Class CW-PG65-FW Size tested 1500 x 1500 (59 x 59)**

Optional secondary designator: Positive Design pressure (DP) = 3120 Pa (65.0 psf)
Negative design pressure (DP) = -3120 Pa (-65.0 psf)
Water penetration resistance test pressure = 510 Pa (10.5 psf)
Canadian air infiltration / exfiltration level = A3 Level

Test completion date: 03/06/2014
Report date: 15/07/2014
Revision date: -
Number of pages: 5

CAN/CSA A440-00 ratings: A3 / B5 / C5

Note: Reference must be made to Air-Ins Inc. complete report for test specimen description and detailed test results.



Prepared by :

Digitally Signed by:

Eric Perron, Tech.

Physical Testing Department
Air-Ins Inc.

Approved by :

Digitally Signed by:

Jean Miller, Eng.

Director, Physical Testing Department
Air-Ins Inc.



AIR-INS inc.

1320, boul. Lionel-Boulet,
Varenes (Québec) J3X 1P7

☎ (450) 652-0838

☎ (450) 652-7588

✉ info@air-ins.com