


PERFORMANCE TESTS IN ACCORDANCE WITH
AAMA/WDMA/CSA 101/I.S.2/A440-08 & A440S1-09




Report No.:
AI-04203-F1

Product Manufacturer:

LEPAGE MILLWORK
141, CHEMIN DES RAYMOND C.P. 1298
RIVIÈRE-DU-LOUP, QUEBEC
G5R 4L9
(418) 862-2611

Test Report Summary:

Product type: Double Hung Window- Vertical Sliding
Product series/model: WH11 Series Wooden Double Hung Window



Primary product designator: **Class R-PG50-H Size tested 1000 x 1600 (39 x 63)**

Optional secondary designator: Positive Design pressure (DP) = 2640 Pa (55.0 psf)
Negative design pressure (DP) = -2640 Pa (-55.0 psf)
Water penetration resistance test pressure = 360 Pa (7.50 psf)
Canadian air infiltration / exfiltration level = A3 Level

Test completion date: 07/03/2014
Report date: 07/07/2014
Revision date: -
Number of pages: 8

CAN/CSA A440-00 ratings: A3 / B4/ C4 / F20 / S1

Note: Reference must be made to Air-Ins Inc. complete report for test specimen description and detailed test results.

Prepared by:

Digitally Signed by:
Jason Michaud, Tech.
Physical Testing Department
Air-Ins Inc.

Approved by :

Digitally Signed by:
Jean Miller, Eng.
Director, Physical Testing Department
Air-Ins Inc.



AIR-INS inc.

1320, boul. Lionel-Boulet,
Varenes (Québec) J3X 1P7

☎ (450) 652-0838

📠 (450) 652-7588

📧 info@air-ins.com